



Awnings & Carports



Incorrect



Incorrect



Awnings & Carports



The awning/carport enclosure is structurally unsound. The side of the structure has been enclosed more than 50 percent. Remove the enclosure or repair to meet minimum structural requirements. [25 CCR 1478(e), 1608(b)]

Per 25 CCR 1474(e) an awning / carport can only be enclosed if it has been designed and constructed to withstand the additional forces imposed by the enclosure