


Project Number	Pipe ID	Existing Diameter (in)	CIP Diameter (in)	Length (ft)	Upstream Manhole	Downstream Manhole	2050 d/D	YEAR to be Upsized	Pipe Material	BASIN	Street
P10	4607	10	18	269	4562	4567	1	2013	Vitrified Clay	Telegraph Canyon	Moss Street
P10	4383	15	18	262	4337	4328	1	2017	Vitrified Clay	Telegraph Canyon	K Street
P10	4418	15	18	434	4369	4337	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd
P10	4453	15	18	446	4409	4369	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd
P10	4500	15	18	444	4455	4409	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd
P10	4535	15	18	443	4492	4455	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd
P10	4566	15	18	427	4525	4492	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd
P10	4608	15	18	454	4567	4525	1	2017	Vitrified Clay	Telegraph Canyon	Industrial Blvd

Legend

Recommended CIP Pipeline Improvement Projects

Project_No

- ▶ P9
- ▶ P10
- Existing Wastewater Collection Pipelines
- Existing Manholes
- City of Chula Vista Roads


 City of Chula Vista
 Wastewater Collection System Master Plan
2050 CIP Pipeline/Manhole Improvements - Area 5
FINAL
 May 2014
Figure 7-6

Source: Esri, DigitalGlobe, GeoEye, i-cubed swisstopo, and the GIS User Community