



0 125 250 Feet



Project Number	Pipe ID	Existing Diameter (in)	CIP Diameter (in)	Length (ft)	Upstream Manhole	Downstream Manhole	2050 d/D	YEAR to be Upsized	Pipe Material	BASIN	Street
P25	6343	8	10	132	6258	6248	0.505	2032	Vitrified Clay	Main Street	E. Rienstra Street
P25	6344	8	10	169	6259	6258	0.574	2032	Vitrified Clay	Main Street	E. Rienstra Street
P25	6345	8	10	319	6260	6259	0.68	2032	Vitrified Clay	Main Street	E. Reinstra Street
P45	6822	8	10	163	6260	6721	0.514	2037	PVC	Main Street	Marl Court
P45	6824	8	10	148	6723	6722	0.661	2037	Vitrified Clay	Main Street	Marl Court

Legend

Recommended CIP Pipeline Improvement Projects

Project_No

- ▶ P25
- ▶ P45
- Existing Wastewater Collection Pipelines
- Existing Manholes
- City of Chula Vista Roads



City of Chula Vista
 Wastewater Collection System Master Plan
2050 CIP Pipeline/Manhole Improvements - Area 25
FINAL
 May 2014
Figure 7-26

Source: Esri, DigitalGlobe, GeoEye, i-cubed, USDA, USGS, AEX, Getmapping, A